IT SHALL BE THE RESPONSIBILITY OF THE

MECHANICAL CONTRACTOR TO INSURE THE UNIT IS INSTALLED LEVEL ON MOUNTING FRAME. UNIT BASE RAIL ROOF MOUNTING FRAME RESILIANT GASKET FURNISHED WITH UNIT. N.R.C.A. APPROVED 26 GAUGE RAIN SHIELD WOOD NAILING STRIP 26 GAUGE COUNTER FLASHING RIGID INSULATION. ROOFING MATERIALS 4" CANT. STRIP. CONTROL & POWER INSIDE CURB. 2" ACOUSTIC FIBERGLASS ROOF CONSTRUCTION SEE ARCHITECTURAL. INSULATION.

## MOUNTING FRAME DETAIL